

Addendum No. 2
November 27, 2018

Project: CHCBH – Mental Health Pod
Rapid City, South Dakota
Arch Project No. : 2765

Architect: Architecture Incorporated

Letting: **Thursday, November 29, 2018**
2:00 PM
East Conference Room (3rd Floor)
City/School Administration Center
300 6th St
Rapid City, South Dakota 57701

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

GENERAL ITEMS:

1) SECTION 095113 – ACOUSTICAL PANEL CEILINGS:

- a) Paragraph 2.5 B. – Metal suspension system: Delete “Hot-Dip Galvanized” requirement. Steel grid to be standard, non-galvanized.

2) SECTION 123216 – INSTITUTIONAL CASEWORK:

- a) Paragraph 2.7 B. Plastic laminate countertops are to be nominal 1 1/8” thick with 3 mm PVC edging and set-on backsplash where post-forming is not feasible.
- b) Add the following paragraph:
 - (1) INTERIOR STANDING AND RUNNING TRIM FOR TRANSPARENT FINISH
 - (a) Grade: [**Custom**].
 - (b) Wood Species and Cut:
 - (i) Species: [**Red oak**].
 - (ii) Cut: [**Plain sliced/plain sawn**].

3) SECTION 31200 – EARTHWORK & GEOTECHNICAL REPORT

- a) Clarification : Alternate #1 Cold Storage Building as indicated on Sheet 4.11 shall comply with the Geotechnical Report requirements for 4-foot overexcavation and imported granular engineered fill under the spread foundations/footings and interior slabs on grade.

GENERAL APPROVALS:

The following material or equipment furnished by the manufacturers listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

| <u>SECTION</u> | <u>ITEM</u> | <u>MANUFACTURER</u> |
|----------------|------------------------|---------------------|
| 123216 | INSTITUTIONAL CASEWORK | Patzer Woodworking |

END OF ADDENDUM