

Addendum No. 4
April 3, 2017

Project: Edison Middle School Window Replacement and Renovation
Sioux Falls, South Dakota

Project No: 2703

Architect: Architecture Incorporated

Letting: **Thursday, April 6, 2017**
2:00 PM
Central Services Center
1101 North Western Avenue
Sioux Falls, South Dakota 57104

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated.

Acknowledge receipt of this addendum by listing its number and date in the bidders Form of Proposal. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as follows:

GENERAL ITEMS:

- 1) SPECIFICATION SECTION 088000 - GLAZING
 - a) Part 1.9, Article 1.9, Item D, Sub-Item 2 – change warranty period to 5 years.

- 2) DRAWING SHEET 5.10
 - a) Window Type Schedule Clarifications:
 - i) Insulated vision glass, insulated spandrel glass and insulated prefinished metal panels shall be glazed from the interior at all Window Types unless noted otherwise below.
 - ii) Window Types ‘F3’ and ‘F4’ – insulated spandrel glass shall be glazed from the exterior.
 - iii) Window Types ‘G’ and ‘H’ – insulated prefinished metal panels shall be glazed from the exterior.

GENERAL APPROVALS:

The following material or equipment furnished by the manufacturer's listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SECTION</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
084433	Sloped Glazing Assemblies	Imperial Glass Structures Company
088000	Prefinished Insulated Spandrel Panels	Laminators Inc. Omega Foam-Ply

MECHANICAL ITEMS:

NA

ELECTRICAL ITEMS:

NA

END OF ADDENDUM