

**Addendum No. 1**  
**February 3, 2020**

Project: Infield Catering Hall Bathroom Repair, South Dakota State Fair  
Huron, South Dakota  
Architecture Incorporated Project Number: 1106.2865.19  
OSE #: M2320—06X/SWMR

Architect: Architecture Incorporated

Letting: February 6, 2020  
2:30 PM Central Time  
Office of the State Engineer  
Joe Foss Building  
523 E. Capitol Avenue  
Pierre, South Dakota 57501-3182

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

**GENERAL ITEMS:**

- 1) PREBID CONFERENCE – See attached Prebid Conference Sign In Sheet.
- 2) ELECTRICAL CLARIFICATIONS
  - a) Conduit shall be concealed behind wall panels and above ceiling panels.
  - b) The existing lights shall be removed and reinstalled in the main area with Alternate #2.
  - c) See Description of Alternates in Section 012300 "Alternates."

END OF ADDENDUM



**2865 – Infield Catering Hall Bathroom Repair, South Dakota State Fair**

<b><u>Name</u></b>	<b><u>Company</u></b>	<b><u>Email</u></b>	<b><u>Phone</u></b>
1. Brandon Carda	OSE	<a href="mailto:brandon.carda@state.sd.us">brandon.carda@state.sd.us</a>	773-3898
2. Shad Wood	Kyburz-Carlson	<a href="mailto:swood@kyburzcarlson.com">swood@kyburzcarlson.com</a>	225-6161
3. Dave Hinker	Muth Electric	<a href="mailto:jhinker@muthelectirc.com">jhinker@muthelectirc.com</a>	350-2391
4. Peggy Besch	SDSF		353-7343
5. Joe Dise	C. Eagle Construction	<a href="mailto:joedise9@gmail.com">joedise9@gmail.com</a>	354-2913
6. Allan Westendorf	Westendorf Electric	<a href="mailto:westendorfelectric@santel.net">westendorfelectric@santel.net</a>	770-4273
7. Scott Bosock	Scotts Plumbing & Heating	<a href="mailto:scott@midstatesd.net">scott@midstatesd.net</a>	730-0738