

**Addendum No. 1**  
**February 21, 2019**

Project: **Norton Hall Renovation**  
University of South Dakota  
Vermillion, South Dakota

OSE Project No: R0619--05X  
Architecture Incorporated Project #: 1121.2820.18

Architect: Architecture Incorporated

Letting: **March 14, 2019**  
**3:00 PM**  
Office of the State Engineer  
Joe Foss Building  
523 East Capitol Ave  
Pierre, South Dakota 57501-3182

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

**GENERAL ITEMS:**

- 1) DRAWING SHEET 4.00 – BASEMENT & FIRST FLOOR DEMOLITION PLANS
  - a) Clarification at Room 441 – existing wall mounted light fixture to remain.
- 2) DRAWING SHEET 4.01 – SECOND & THIRD FLOOR DEMOLITION PLANS
  - a) At Rooms 520 and 620, salvage closers from doors being removed. Closers shall be reinstalled on new doors.
- 3) DRAWING SHEET 4.11 – FIRST FLOOR PLAN
  - a) Paint stair risers at stairs in Room 138B.
- 4) DRAWING SHEET 4.40 – ENLARGED FLOOR PLANS
  - a) Accessory Schedule – change note 4 to note 5 at accessories T6 and T11.
  - b) Room 010 – provide toilet accessory T17 at north wall.
- 5) DRAWING SHEET 5.20 – BUILDING SECTIONS
  - a) Detail 4/5.20 – add the note “ALUMINUM WINDOW SILL BY CURTAIN WALL FRAMING SUPPLIER”. Sill to match curtain wall and be provided between the bottom of the curtain wall system and existing construction.

6) DRAWING SHEET 6.10 – BASEMENT & FIRST REFLECTED CEILING PLANS

- a) Corridor 499A – paint existing return diffuser.

**MECHANICAL ITEMS:**

NA

**ELECTRICAL ITEMS:**

1) DRAWING SHEET 9.00 – ELECTRICAL DEMOLITION PLANS

- a) Electrical Basement Demolition Plan – Men 010: the smoke detector is Existing to Remain.

2) DRAWING SHEET 9.10 – ELECTRICAL PLANS

- a) Electrical Basement Plan – Men 010: the smoke detector is Existing to Remain.
- b) Electrical First Floor Plan – Stair S101: Type X1 shall be ceiling mount in lieu of wall mount.
- c) Electrical First Floor Plan – Stair S102: Type X1 shall be ceiling mount in lieu of wall mount.

3) DRAWING SHEET 9.20 ELECTRICAL DETAILS AND SCHEDULES

- a) Door Security/Access System Detail – Eliminate Door access at Door 499C.

**GENERAL APPROVALS:**

The following material or equipment furnished by the manufacturers listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SECTION</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
----------------	-------------	---------------------

NA

END OF ADDENDUM