

Addendum No. 2
May 8, 2017

Project: BHSU Bookstore Renovation
Black Hills State University
Spearfish, South Dakota
OSE # R0815-21X

Architect's Project No.: 2620

Architect: Architecture Incorporated

Letting: Date: **May 11, 2017**
Time: **2:00 P.M. CT**

Office of the State Engineer
Joe Foss Building
523 East Capitol Avenue
Pierre, SD 57501-3182

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated.

Acknowledge receipt of this addendum by listing its number and date in the bidders Form of Proposal. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as follows:

GENERAL ITEMS: No General architectural items.

MECHANICAL ITEMS: No mechanical items.

ELECTRICAL ITEMS: See attached Addendum #2 from West Plains Engineering for Electrical Addendum items.

GENERAL APPROVALS:

The following material or equipment furnished by the manufacturer's listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SECTION</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
102239.13	Folding Glass-Panel Partitions	Solar Innovations SI 1300 C

END OF ADDENDUM No. 2



ADDENDUM #2

RAPID CITY

1750 Rand Road ■ Rapid City, SD 57702
Ph: (605) 348-7455 ■ Fax (605) 348-9445

Date: May 8, 2017

To: Architecture Incorporated
815 St. Joseph Street, Ste. 203
P.O. Box 8047
Rapid City, SD, 57702

From: West Plains Engineering
1750 Rand Road
Rapid City, SD 57702

Project: BHSU Bookstore

TO: All prime contract bidders and all others to whom Drawings and Specifications have been issued by the Engineer. Acknowledge receipt of the Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as follows:

DRAWINGS:

SHEET 9.2

1. Electrical Miscellaneous Note F: In lieu of bringing conduit and cable back to existing wall mounted data rack in Storage 8, route the conduit and cable back to existing data rack in IT closet across the Hall 20 from the existing electrical room.

End of Addendum #1

MKV;/mkv