

**Addendum No. 3**  
**June 5, 2020**

Project: Wegner Library Renovation  
University of South Dakota  
Sanford School of Medicine  
Sioux Falls, South Dakota  
OSE Project #R0620--21X  
Architecture Incorporated Project #2875

Architect: Architecture Incorporated

Letting: Thursday, June 11, 2020  
2:00 P.M.  
Office of the State Engineer, Joe Foss Building, 523 East Capitol, Pierre, South Dakota

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

**GENERAL ITEMS:**

- 1) SPECIFICATION SECTION 011000 – SUMMARY
  - a) Part 1.9.B.4.b – Note the Owner has identified additional testing dates of August 10 **through** August 14, 2020 at Room 143. The Contractor shall plan that there will be no construction related activity on the project during this week. A path of public access/egress to/from Room 101 and Room 143 shall be available and all life safety systems shall be fully operational during this period of time.
- 2) SPECIFICATION SECTION 084113 – ALUMINUM-FRAMED ENTRANCES & STOREFRONTS
  - a) Part 2.3.A.3 – Color of aluminum framing to be manufacturer's standard Class 1, color anodize to match existing aluminum framing color as close as possible. Existing color is light bronze.
- 3) SPECIFICATION SECTION 105113 – METAL LOCKERS
  - a) Part 2.3.J.1 – Clarification – tops, bottoms, backs, sides, and shelves shall be 24 gage (.024 inches).
- 4) DRAWING SHEET 6.11 – SECOND FLOOR REFLECTED CEILING PLAN
  - a) Clarification – existing drawings indicate that roof deck joist bearing is 16'-0" above the second floor at Rooms 289A and 289B.

**MECHANICAL ITEMS:**

NA

**ELECTRICAL ITEMS:**

NA

**GENERAL APPROVALS:**

The following material or equipment furnished by the manufacturers listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SECTION</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
----------------	-------------	---------------------

NA

END OF ADDENDUM