

**Addendum No. 3
December 30, 2020**

Project: **Student Service Phased Renovations – Phase 2**
University Student Union
South Dakota State University
Brookings, South Dakota
OSE Project No: R0320--25X
Project No: 1025.2817.18

Architect: Architecture Incorporated

Letting: Thursday, January 7, 2021
3:00 P.M.
Office of the State Engineer, Joe Foss Building, 523 East Capitol Ave, Pierre, South Dakota

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

GENERAL ITEMS:

NA

MECHANICAL ITEMS:

NA

ELECTRICAL ITEMS:

- 1) DRAWING SHEET 9.23 – PARTIAL SECOND FLOOR PLAN – POWER & SIGNAL
 - a) In reference to Pasque Room 255, provide backbox and (2) empty 0.5” conduit raceways at entry door location stubbed up to an accessible ceiling cavity to support installation of an owner provided room scheduling panel. Coordinate exact location and requirements with owner at time of door installation.

GENERAL APPROVALS:

The following material or equipment furnished by the manufacturers listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SECTION</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
265119	Light Fixtures	<i>See Below:</i>
	Type A, A2	Lithonia
	Type B2, B4	Vode
	Type C, C2, C4, C8	Lithonia
	Type CX1, CX2, CX3, CX4, CX7, CCX9	Lithonia
	Type E1, E2, E3, E4, E5	Evenlite
	Type F	LLED
	Type P1, P2, P3	CoronetLED
	Type P4	ERKA
	Type P5	Luminis
	Type P6	Barbican
	Type P7	ERKA
	Type S1, S2, S3, S4	
261450	Lighting Control Devices	Nlight, Acuity Controls, SensorSwitch

END OF ADDENDUM